



## **Declaration of Conformity**

For the following equipment:			
Product Name: Switching Power Supply			
Model Designation: TDR-480-X(X=24,48)			
is herewith confirmed to capplied:  RoHS Directive (2011  Low Voltage Directive (	•	in the Council Directi	ve, the following standards were
EN60950-1:2006+A1 +A2-	,	CB certificate No	: DK-59655-UL
Electromagnetic Comp EMI (Electro-Magnetic In Conducted emission / Rad			class B
Harmonic current	EN61000-3-2:2014		
Voltage flicker	EN61000-3-3: 2013		
EMS (Electro-Magnetic S	usceptibility)		
EN55024:2010+A1:2015	EN61204-3:2000 EN61000-6-2:20	05	
ESD air	EN61000-4-2:2009	Level 4	15KV
ESD contact	EN61000-4-2: 2009	Level 4	8KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2	010 Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014	Level 4	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2014	Level 4	4KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltage dip, interruption	EN61000-4-11:2004 >95% dip 0.5 perio	ods 30% dip 25 periods	>95% interruptions 250 periods
Note:  The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.  For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).			
This Declaration is effective from serial number EB7xxxxxxx			
Person responsible for marking this declaration:			
MEAN WELL Enterprises Co., Ltd.			
(Manufacturer Name) No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan			
(Manufacturer Address)	1		MICO
Johnny Huang/Manager, Certific (Name / Position)	cation Center : (Signature)	Ted Cheng/Director, Sal (Name / Position)	es Dept. :(Signature)
Taiwan (Place)	Mar. 29th, 2017 (Date)		~