



Declaration of Conformity

For the following equipment:					
Product Name: Switching Power Supplies					
Model Designation: TDR-960-X(X=24,48)					
is herewith confirmed to coapplied: RoHS Directive (2011 Low Voltage Directive (/65/EU)	ents set out ir	n the Council Direct	ive, the foll	owing standards were
EN60950-1:2006+A1:2010+A2:2013+A11:2009+A12:2011					
Electromagnetic Comp EMI (Electro-Magnetic Int Conducted emission / Radi	erference)	14/30/EU):		Clas	ss B
Harmonic current	EN61000-3-2:2014				
Voltage flicker	EN61000-3-3:2013				
EMS (Electro-Magnetic S	usceptibility)				
EN55024:2010 EN61204	-3:2000 EN61000-6-2:2	2005			
ESD air	EN61000-4-2:2009		Level 4	15KV	
ESD contact	EN61000-4-2: 2009		Level 4	8KV	
RF field susceptibility	EN61000-4-3:2006+A1	:2008+A2:201	0 Level 3	10V/m	
EFT bursts	EN61000-4-4:2012		Level 3	2KV/5KH	lz
Surge susceptibility	EN61000-4-5:2006		Level 3	2KV/Line	-Line
Surge susceptibility	EN61000-4-5:2006		Level 4	4KV/Line	-Earth
Conducted susceptibility	EN61000-4-6:2014		Level 3	10V	
Magnetic field immunity	EN61000-4-8:2010		Level 4	30A/m	
Voltage dip, interruption	EN61000-4-11:2004 >959	% dip 0.5 period	s 30% dip 25 periods	>95% intern	uptions 250 periods
Note: The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).					
This Declaration is effective from serial number RB6xxxxxxx					
Person responsible for marking this declaration :					
MEAN WELL Enterprises (Manufacturer Name)	Co., Ltd.				
No.28, Wuquan 3rd Rd., W (Manufacturer Address) Johnny Huang/Manager, Certific (Name / Position)		y 248, Taiwan	Ted Cheng/Director, Sa (Name / Position)	les Dept. :	Signature)
Taiwan (Place)	Apr. 20th, 20 (Date)	16			(Signaturo)