



Declaration of Conformity

For the following equipmen	nt:		
Product Name: Switching	Power Supplies		
Model Designation: NDR -	120x (x=12,24,48)		
is herewith confirmed to c were applied :	comply with the requirements s	set out in the Council	Directive, the following standards
RoHS Directive (2011	/65/EU)		
Low Voltage Directive (2014/35/EU):			
EN60950-1:2006+A11+A1+A12+A2 TUV certificate No : R50291025			
Electromagnetic Comp EMI (Electro-Magnetic In Conducted emission / Rad		0/EU) :	Class B
Harmonic current	EN61000-3-2:2006+A1:2009)+A2:2009	
Voltage flicker	EN61000-3-3:2013		
EMS (Electro-Magnetic S	Susceptibility)		
EN55024:2010			
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008	8+A2:2010 Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2006	Level 3	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2006	Level 4	4KV/Line-FG
Conducted susceptibility	EN61000-4-6:2009	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 3	30A/m
Voltage dip, interruption	EN61000-4-11:2004 >95% dip	0.5 periods 30% dip 25 p	eriods >95% interruptions 250 periods
performance will be affected be complete installation again.		l equipment manufacture	on with final equipment. Since EMC is must re-qualify EMC Directive on the entation File).
This Declaration is effective from serial number EB6xxxxxxx			
Person responsible for ma	rking this declaration:		
MEAN WELL Enterprises	Co., Ltd.		
(Manufacturer Name)			
No.28, Wuquan 3rd Rd., W (Manufacturer Address)	/ugu Dist., New Taipei City 248	, Taiwan	MIRO
Johnny Huang/Manager, Certific (Name / Position)	cation Center : (Signature)	Ted Cheng/Director, Sa (Name / Position)	ales Dept.: (Signature)
Taiwan (Place)	Apr. 20th, 2016 (Date)		
u iauti	(Date)		