



| Declaration of Conformity | | | | |
|--|-----------------------------------|-----------------------|--------------------------------------|--|
| For the following equipment: | | | | |
| Product Name: True Sine Wave DC-AC Inverter | | | | |
| Model Designation: Tx-1500-2yz(x=N or S; y=12,24,48; z=B,C,D) | | | | |
| is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied: | | | | |
| RoHS Directive (2011/65/EU) | | | | |
| Low Voltage Directive (2014/35/EU): | | | | |
| EN60950-1:2006+A11+A1+A12+A2 LVD (| | LVD certificate No : | ertificate No: PSE102-1245-6 | |
| Electromagnetic Compatibility Directive (2014/30/EU): EMI (Electro-Magnetic Interference) Conducted emission / Radiated emission EN55022:2010 Class B | | | | |
| Harmonic current | EN61000-3-2:2006+A1:2009+A2 | :2009 | | |
| Voltage flicker | EN61000-3-3: 2013 | | | |
| EMS (Electro-Magnetic S | usceptibility) | | | |
| EN55024:2010 | | | | |
| ESD air | EN61000-4-2:2009 | Level 3 | 8KV | |
| ESD contact | EN61000-4-2:2009 | Level 2 | 4KV | |
| RF field susceptibility | EN61000-4-3:2006+A1:2008+A2 | :2010 Level 2 | 3V/m | |
| EFT bursts | EN61000-4-4:2012 | Level 2 | 1KV/5KHz | |
| Surge susceptibility | EN61000-4-5:2006 | Level 2 | 1KV/Line-Line | |
| Surge susceptibility | EN61000-4-5:2006 | Level 3 | 2KV/Line-Earth | |
| Conducted susceptibility | EN61000-4-6:2009 | Level 2 | 3V | |
| Magnetic field immunity | EN61000-4-8:2010 | Level 2 | 3A/m | |
| Voltage dip, interruption | EN61000-4-11:2004 >95% dip 0.5 pe | eriods 30% dip 25 per | riods >95% interruptions 250 periods | |
| Note: The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again. For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File). | | | | |
| This Declaration is effective from serial number RB6xxxxxxx | | | | |
| Person responsible for marking this declaration : | | | | |
| MEAN WELL Enterprises Co., Ltd. | | | | |
| (Manufacturer Name) | | | | |
| No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan (Manufacturer Address) | | | | |
| Johnny Huang/Manager, Certification Center: (Name / Position) Ted Cheng/Director, Sales Dept.: (Name / Position) (Signature) (Signature) (Signature) | | | | |

Apr. 20th, 2016

(Date)

Taiwan

(Place)